

MOPC EDUCATION SESSION:

FUEL ASSURANCE AND ACAP PRM OVERVIEW

Working together to responsibly and economically keep the lights on today and in the future.

(f)




RR 621: FUEL ASSURANCE OVERVIEW



Exhibit JFM-2 Page 3 of 17

WHAT IS THE FUEL ASSURANCE MECHANISM?

system periods"





SAWG APPROVED MECHANISM

Fuel Assurance Allocation Mechanism (Option A) To all units that have EFOF

	Performance Based Accreditation Policy	Fuel Assurance Policy
Unit Accredited Capacity _i =	$capacity_i \cdot (1 - EFORd')$ -	Seasonal Correlated Outages \cdot Critical Period Allocator _i

 $Critical \ Period \ Allocator_{i} = \frac{Unit \ incremental \ nonperformance}{fleet \ incremental \ nonperformance} = \frac{EFOF_{i} * capacity_{i}}{\sum_{i=1}^{n} EFOF_{i} * capacity_{i}}$

EFOF_i is the unit 7 year EFOF EFORd'_i is the unit 7 year EFORd' Seasonal Correlated Outages is from the LOLE Study and refreshed every two years



NEW TARIFF DEFINITIONS

Conventional Resource Performance Adjustment

• The historical performance adjustment for conventional resources using the combination of a modified demand Equivalent Forced Outage Rate ("EFORd") method and Equivalent Forced Outage Factor ("EFOF") method adjusted for Incremental Outage Impact in accordance with this Attachment AA and the SPP Business Practices. A resource's EFOF shall only be considered during the Winter Season. Conventional resources are defined as thermal fuel type resources, pump storage hydroelectric resources, and hydroelectric resources with reservoir storage capability not subject to hourly river flow limitations similar to run-of-river hydro.

Incremental Outage Impact

 The incremental impact of simultaneous conventional resource forced outages in excess of the normally modeled forced outages experienced during timeframes of extreme temperatures from the LOLE Study. This value shall be assessed in accordance with the LOLE Study scope and SPP Business Practices. Incremental Outage Impact shall only be considered during the Winter Season.

EFOF will only apply unit performance to the Winter Season



EFORD METHODOLOGY

Determined on an individual historical year basis

Averaged together considering all appropriate historical years for the applicable season

A resource's seasonal EFORd includes events occurring during the entire applicable season and exclude OMC events, as defined by NERC

SPP will calculate and post a weighted class average EFORd for each applicable season

Resources weighted against all other resources in the same class for determining class average EFORd



EFOF METHODOLOGY

Determined on an individual historical year basis and averaged together considering all appropriate historical years for the applicable season



Includes events occurring during the top three percent (3%) Adjusted Net Peak Load hours

• Applicable season for each historical year

SPP calculate and post a weighted class average EFOF for each applicable season

- The resources weighted against all other resources in the same class for determining class average EFOF
- The class average EFOF calculated prior to the application of Incremental Outage Impact



Exhibit JFM-2 Page 8 of 17

EFOF INCREMENTAL OUTAGE IMPACT (IOI)

EFOF further adjusted for Incremental Outage Impact The IOI determined by SPP on a biennial basis in accordance with the LOLE Study scope The impact on the Base PRM with and without the modeled incremental correlated forced outages calculates and sets the Incremental Outage Impact In the event SPP does not determine a resource's EFOF prior to the first season the resource is qualified

 Resource's EFOF determined by the entity not adjusting Incremental Outage Impact for the first applicable season

SPP 8

WHAT IF HISTORICAL DATA IS NOT PROVIDED?



Resources internal to the SPP where historical performance data exists but is not provided for the applicable season receive no accreditation for the historical year




Once a resource has been qualified, the historical data must continually be submitted to avoid 100% EFORd and EFOF applied to the applicable historical year





METHODOLOGY FLOW



10

WINTER ACCREDITED CAPACITY EXAMPLE 100 MW UNIT

NGC = Net Generating Capability ACAP = Accredited Capacity

$$Unit \ ACAP = NGC * \left(1 - \left(EFORd\% + EFOF\% * \frac{Incremental \ Outage \ Impact}{Sum \ of \ EFOF \ capacity \ from \ all \ units} \right) \right)$$

$$Unit ACAP = 100 * \left(1 - \left(10\% + 20\% * \frac{4,102}{7,100} \right) \right) = 78.4 MW$$





BASE PRM VS ACCREDITED CAPACITY (ACAP) PRM OVERVIEW



BASE VS ACCREDITED CAPACITY PRM OVERVIEW

Base PRM

RSC/BOD approves

Based on installed capacity values for conventional resources and ELCC values for renewable and energy limited resources

Stays static between LOLE study years

Is the foundation for calculation of the ACAP PRM %

No enforcement mechanism applied on this %

Reliability needs based on BA (SPP) level

ACAP PRM

Does not require RSC/BOD approval

Capacity value based on PBA and FA for conventional resources and ELCC values for renewable and energy limited resources

Changes annually based on performance

Resource Adequacy Requirement is enforced on this %

Applied for resource planning on entity level




SYSTEM WINTER SEASON PRM IMPACT EXAMPLE **BASE PRM 36%**

Demand and PRM values from 2023

	Variable			Wi	nter		LOLE Study	/ for Ye	ar
Determine Base	Summation	ation of LRE Peak Demand			47,822		202	26	
PRM Impact	Winter Base	PRM		3	6%				
	Calculated R	Summation of LRE Peak Demand 47,822 2026 Winter Base PRM 36% Calculated Required Capacity 65,038 Variable Winter Summation of Conv. Resources PBA EFORd Impacts 6,844 Summation of Conv. Resources PBA FA Impacts 4,102 Total PBA Impact from all conventional resources 10,946 Reduce Required Capacity to account for PBA Calculated Required Capacity after PBA Impacts (Conventional resources accreditation reduction) 54,092 ed A is still on Variable Variable Vinter Calculate ACAP PRM Calculate ACAP PRM Summation of LRE Peak Demand 47,822	Calculated Required Capacity						
						er	consider all resources in	convent footprin	ional it, not
	Determine PBA,	,		•					
	and FA Impacts	Summation of C	Conv. Resources PBA FA I	mpacts	4,10	2	claiming for winter sea		
		Total PBA Impa	Winter on of Conv. Resources PBA EFORd Impacts 6,844 on of Conv. Resources PBA FA Impacts 4,102 Impact from all conventional resources 10,946 Variable Winter Calculated Required Capacity 65,038 Total PBA Impact from all conventional resources 10,946 Required Capacity after PBA Impacts 54,092						
			Variable				Wint	er	
		Reduce Required	Calculated Required	Capacity			65,03	88	t has to ntional nt, not season season nter ,092 ,822
			Total PBA Impact fro	m all conve	ntional res	ources	10,94	16	
		account for PBA				tion)	54,09	92	
Calculated Requ						-			
Capacity for the									
65,038 MW base	ed on		alculate ACAP Req	ired Capac	ity after PE	BA Impacts		54,0)92
"nameplate"	<i>C</i> .		PRM Sum	mation of L	RE Peak De	emand		47,8	322
conventional, ev			ACA	P PRM [(Ca	pacity – De	emand) / Den	nand]	13.	1%
considering PBA								<u></u> 9L	14

Exhibit JFM-2 Page 14 of 17

CALCULATING THE SYSTEM WINTER ACAP PRM



Variable	No PBA	PBA Only	PBA + FA
LRE Peak Demand	47,822	47,822	47,822
Base PRM	36%	36%	36%
Required Capacity	65,038	65,038	65,038
PBA Impact (EFORd)	0	6,844	6,844
Fuel Assurance Impact (Adjusted EFOF)	0	0	4,102
Total PBA Impact	0	6,844	10,946
Required Capacity after PBA Impact	65,038	58,194	54,092
System ACAP PRM	N/A	21.7%	13.1%

PBA Reduction Impact must consider all conventional resources in footprint, not just what entities are claiming for winter season



Impact calculations were sent to individual LREs

APPLYING ACAP PRM TO EXAMPLE LRE

Applied to Winter only

Variable	Winter	Summer
LRE Peak Demand	1,000	1,100
Capacity Resources*	1,200	1,200
PBA Impact (EFORd)	90	90
Fuel Assurance Impact (Adjusted EFOF)	40	0
Total PBA Impact	130	90
Capacity Resources (ACAP)	1,070	1,110
System ACAP PRM	13.1%	7.36%
Resource Adequacy Requirement	1,131	1,181
Excess Capacity	-61	-71

Capacity Resources	Nameplate/Rating	Winter ACAP	Summer ACAP	
Natural Gas Facility (PBA)	800 MW	680 MW	720 MW	
Natural Gas Resource (PBA)	100 MW	90 MW	90 MW	
Wind Resources (ELCC)	1,200 MW	300 MW	300 MW	

16

QUESTIONS?

PLEASE SEND FOLLOW UP REQUEST VIA EMAIL TO RESOURCEADEQUACY@SPP.ORG

